

Clerk's Report – August

During August, several works and checks have been carried out at the hall.

- The **Gas Safe Certificate** has been completed.
- **PAT Testing** has been carried out and the relevant certificate received.
- A **Fire Risk Assessment** has been completed.
- Actions identified in the **Health and Safety Report from 2024** have mostly been addressed. However, this remains a work in progress, and any outstanding actions will continue to be dealt with.
- An **EICR (Electrical Installation Condition Report)** and hard-wiring check have been carried out. Unfortunately, the installation did not pass. A new motherboard is required, along with safety switches to be fitted to all sockets. This work will be arranged and carried out on my return.
- All outstanding actions identified in the reports received will be addressed on my return.

Work has also commenced on **cutting back the trees and tidying the garden areas** around the hall. This work will continue to improve the appearance and general upkeep of the grounds.

The new **Memorial Stone** has now been installed.

New **Cooker** and **Hob** are now installed

New **Hand Dryers** and **Heaters** have been installed in the toilets. Old heaters and dryers have now been disposed of.

K Newton 13/09/2026